

## ATTACHMENT - Facility Information

### Transmontaigne Operating Company LP GCM-0200-0057 Page 1 of 2

#### GENERAL INFORMATION

##### A - APPLICABLE PERMIT DATES

COVERAGE DATE: October 1, 2012

##### B - FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 14033 Highway 20 North  
CITY, STATE, ZIP FACILITY IS LOCATED IN: Belton, SC 29627  
COUNTY FACILITY IS LOCATED IN: Anderson

##### C - EQUIPMENT INSTALLED

Equip ID	Exempt Yes / No	Equipment Description	Maximum Size / Maximum Throughput	Fuels Used/ Materials Handled	Installation Date/ Modification Date	Emission Point ID
LR	No	Loading Rack (5 bottom loading bays with two which can operate as top loading) (40 CFR 60, Subparts A and XX when in gasoline service) (40 CFR 63 Subparts A and BBBBBB when in gasoline service)	---	Gasoline/Distillate	1996	VRU
8301	No	External floating roof storage tank (40 CFR 63 Subparts A and BBBBBB)	36,000 barrel (1.512 x 10 <sup>6</sup> gallons)	Gasoline	1957	8301
8302	No	External floating roof storage tank (40 CFR 63 Subparts A and BBBBBB)	36,000 barrel (1.512 x 10 <sup>6</sup> gallons)	Gasoline	1957	8302
8304	No	External floating roof storage tank (40 CFR 63 Subparts A and BBBBBB)	20,000 barrel (0.84 x 10 <sup>6</sup> gallons)	Gasoline	1957	8304
8306	No	External floating roof storage tank (40 CFR 63 Subparts A and BBBBBB)	20,000 barrel (0.84 x 10 <sup>6</sup> gallons)	Gasoline	1957	8306
8307	No	External floating roof storage tank (40 CFR 63 Subparts A and BBBBBB)	10,000 barrel (0.42 x 10 <sup>6</sup> gallons)	Gasoline	1957	8307
8308	No	Internal floating roof storage tank (40 CFR 63 Subparts A and BBBBBB)	10,000 barrel (0.42 x 10 <sup>6</sup> gallons)	Gasoline	1957	8308
8309	No	Internal floating roof storage tank (40 CFR 63 Subparts A and BBBBBB)	15,000 barrel (0.63 x 10 <sup>6</sup> gallons)	Gasoline	1957	8309
8311	No	External floating roof storage tank (40 CFR 63 Subparts A and BBBBBB)	96,000 barrel (4.032 x 10 <sup>6</sup> gallons)	Gasoline	1957	8311
8303	Yes	Fixed roof storage tank	36,000 barrel (1.512 x 10 <sup>6</sup> gallons)	Distillate	1957	8303

**ATTACHMENT - Facility Information**

**Transmontaigne Operating Company LP  
GCM-0200-0057  
Page 2 of 2**

**C - EQUIPMENT INSTALLED**

Equip ID	Exempt Yes / No	Equipment Description	Maximum Size / Maximum Throughput	Fuels Used/ Materials Handled	Installation Date/ Modification Date	Emission Point ID
8305	Yes	Fixed roof storage tank	20,200 barrel (848,400 gallons)	Distillate	1957	8305
8314	Yes	OGA 480 tank	21,153 gallons	Gasoline Additive	Pre-1997	N/A
8315	Yes	OGA 402 tank	6,000 gallons	Gasoline Additive	Pre-1997	N/A
8391	Yes	Tank	2,000 gallons	Diesel Additive	Pre-1997	N/A
8310	Yes	Recovered product tank	10,665 gallons	Gasoline/Distillate	Pre-1997	N/A
8390	Yes	Tank	300 gallons	Diesel Additive	Pre-1997	N/A
8316	Yes	Tank	275 gallons	Distillate Additive	Pre-1997	N/A

**D - CONTROL DEVICES**

Control Device ID	Equipment ID	Control Device Description	Installation Date/ Modification Date	Pollutant(s) Controlled
CD-VRU	LR	Carbon Adsorption Gasoline Vapor Recovery Unit (40 CFR 60, Subparts A and XX when in gasoline service) (40 CFR 63 Subparts A and BBBBBB when in gasoline service)	1996	VOC/HAP

**E – ADDITIONAL CONDITIONS**

The owner/operator must comply with the conditions of the General Conditional Major Operating Permit for Petroleum Distribution Operations and any additional conditions listed in this section.

Condition Number	Conditions
E.1	An initial source test for VOC emissions shall be conducted within 180 days after placing the loading rack and associated vapor recovery unit in gasoline service and every four (4) years thereafter. The source test will be used to verify emissions, control efficiency, etc.

**RECORD OF REVISIONS**

Revision Date	Description of Change
06-21-2013	Added 40 CFR 60 Subparts A and XX to Equipment LR. Removed SC Regulation 61-62.5 Standard 5, Part T from Equipment ID LR. Removed SC Regulation 61-62.5 Standard 5, Part O from Equipment ID's 8305, 8308, and 8309. Removed SC Regulation 61-62.5 Standard 5, Part P from Equipment ID's 8301, 8302, 8304, 8306, 8307, and 8311.
06-24-2014	Added 40 CFR 60, Subparts A and XX and 40 CFR 63 Subparts A and BBBBBB to Equipment CD-VRU when in gasoline service. Added condition E.1.
01-28-2015	Modified Emission Rates for Ambient Air Standards Attachment to reflect other permit templates.

**ATTACHMENT - Emission Rates for Ambient Air Standards**

**Transmontaigne Operating Company LP  
GCM-0200-0057  
Page 1 OF 1**

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards.

<b>TOXIC AIR POLLUTANTS - STANDARD NO. 8</b>						
<b>Emission Point ID</b>	<b>Emission Rates (lbs/hr)</b>					
	<b>Benzene 71-43-2</b>	<b>Ethyl Benzene 100-41-4</b>	<b>Hexane 110-54-3</b>	<b>Toluene 108-88-3</b>	<b>Trimethylpentane 540-84-1</b>	<b>Xylene 1330-20-7</b>
8301	0.0205	0.00231	0.0366	0.0311	0.0184	0.0121
8302	0.0205	0.00231	0.0366	0.0311	0.0184	0.0121
8304	0.0205	0.00231	0.0366	0.0311	0.0184	0.0121
8306	0.0205	0.00231	0.0366	0.0311	0.0184	0.0121
8307	0.0102	0.00115	0.0183	0.0156	0.00922	0.00605
8308	0.00509	0.000574	0.0091	0.00774	0.00458	0.00301
8309	0.00509	0.000574	0.0091	0.00774	0.00458	0.00301
8311	0.0115	0.00129	0.0205	0.0174	0.0103	0.00678
VRU	0.0893	0.0101	0.1598	0.1359	0.0805	0.0528