

ATTACHMENT - Facility Information

US Naval Hospital Beaufort GCM-0360-0005 Page 1 of 1

GENERAL INFORMATION

A - APPLICABLE PERMIT DATES

COVERAGE DATE: April 1, 2011

B - FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 1 Pinckney Blvd.
CITY, STATE, ZIP FACILITY IS LOCATED IN: Beaufort, SC 29902
COUNTY FACILITY IS LOCATED IN: Beaufort

C - EQUIPMENT INSTALLED

Equipment ID	Equipment Description	Fuels Used	Installation Date	Modification Date	Emission Point ID
Boiler #1	14.6 Million BTU/hr Brookes-Cleaver Boiler	Natural Gas No. 2 Fuel Oil ($\leq 0.05\%$ sulfur content by weight)	1986	None	Boiler 1
Boiler #2	14.6 Million BTU/hr Brookes-Cleaver Boiler	Natural Gas No. 2 Fuel Oil ($\leq 0.05\%$ sulfur content by weight)	1986	None	Boiler 2
Boiler #3	14.6 Million BTU/hr Brookes-Cleaver Boiler	Natural Gas No. 2 Fuel Oil ($\leq 0.05\%$ sulfur content by weight)	1986	None	Boiler 3

D – ADDITIONAL CONDITIONS - Reserved

RECORD OF REVISIONS FOR GCM-0360-0005	
Final Revision Date	Description of Change
11-27-2013	Updated exempt sources table. ID EX-GENX03 only have two generators, EX-GENX04 is out of service, EX-GENX06 capacity of generator is 750 kW and was installed on 5/12/88, EX-GENX09 and EX-GENX10 capacities are 66 kW each.
04-01-2014	Updated Template and removed exempt sources
02-06-2015	Updated ATTACHMENT - Emission Rates for Ambient Air Standards

ATTACHMENT - Emission Rates for Ambient Air Standards

US Naval Hospital Beaufort GCM-0360-0005 Page 1 of 1

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2				
Emission Point ID	Emission Rates (lbs/hr)			
	PM ₁₀	SO ₂	NO ₂	CO
Boiler 1	1.65	10	2.1	0.5
Boiler 2	1.65	10	2.1	0.5
Boiler 3	1.65	10	2.1	0.5