

ATTACHMENT - Facility Information

Resort Services Inc.

GCM-0360-0046

Page 1 of 1

GENERAL INFORMATION

A - APPLICABLE PERMIT DATES

COVERAGE DATE: April 1, 2011

B - FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 336 Buck Island Rd.
CITY, STATE, ZIP FACILITY IS LOCATED IN: Bluffton, SC 29910
COUNTY FACILITY IS LOCATED IN: Beaufort

C - EQUIPMENT INSTALLED

Equipment ID	Equipment Description	Fuels Used	Installation Date	Modification Date	Emission Point ID
Boiler #1	25.2 Million BTU/hr Continental Boiler	Natural Gas No. 2 Fuel Oil ($\leq 0.05\%$ sulfur content by weight) No. 5 or No. 6 Fuel Oil ($\leq 2.1\%$ sulfur content by weight)	1983	02-25-1995	Boiler 1
Boiler #2	15.8 Million BTU/hr Continental Boiler	Natural Gas No. 2 Fuel Oil ($\leq 0.05\%$ sulfur content by weight) No. 5 or No. 6 Fuel Oil ($\leq 2.1\%$ sulfur content by weight)	1979	02-25-1995	Boiler 2
Boiler #3	25.2 Million BTU/hr Cleaver Brooks Boiler NSPS A and Dc	Natural Gas No. 2 Fuel Oil ($\leq 0.05\%$ sulfur content by weight)	1995	None	Boiler 3

RECORD OF REVISIONS FOR GCM-0360-0046	
Revision Date	Description of Change
04-01-2014	Updated template and removed exempt source list
10-10-2014	Corrected Coverage Date from March 30, 2011 to April 1, 2011
02-06-2015	Updated ATTACHMENT - Emission Rates for Ambient Air Standards

ATTACHMENT - Emission Rates for Ambient Air Standards

Resort Services Inc.

GCM-0360-0046

Page 1 OF 1

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2				
Emission Point ID	Emission Rates (lbs/hr)			
	PM₁₀	SO₂	NO₂	CO
Boiler 1	3.16	52.9	9.17	0.83
Boiler 2	1.98	33.1	5.75	0.52
Boiler 3	0.18	12.73	3.59	0.90