

## ATTACHMENT - Facility Information

### Beaufort-Jasper Water and Sewer Authority

**GCM-0360-0050**

**Page 1 of 1**

COVERAGE DATE:

January 1, 2012

#### FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS:

14 Snake Road

CITY, STATE, ZIP FACILITY IS LOCATED IN:

Okatie, SC 29909

COUNTY FACILITY IS LOCATED IN:

Beaufort

Equipment ID	Equipment Description	Fuels Used	Installation Date	Modification Date	Emission Point ID
DG01	766 kW Caterpillar Generator, model 3508DI	No. 2 Fuel Oil (maximum sulfur content 0.05% or less)	1991	None	1
DG02	1356 kW Caterpillar Generator, model 3512TA	No. 2 Fuel Oil (maximum sulfur content 0.05% or less)	1999	None	2

#### EXEMPT SOURCES

Equipment ID	Equipment Description	Installation Date	Modification Date	Basis
A	One (1) 250 kW Emergency Generator	2008	N/A	SC Regulation 61-62.1 Section II(B)(2)(f)(ii)
B	Two (2) 2,500 gallon fuel storage tanks (ultra-low sulfur diesel)	2008	N/A	SC Regulation 61-62.1 Section II(B)(2)(h)

#### ADDITIONAL CONDITIONS

The owner or operator must comply with the conditions of the General Conditional Major Operating Permit for Fuel Combustion Operations and any additional conditions listed in this section.

Condition Number	Conditions
1.	The generators are each limited to 500 hr/yr operation in order to be exempt from demonstrating compliance through air dispersion modeling or other method the facility's operations will not interfere with the attainment and maintenance of any state or federal ambient air standard. The owner/operator must equip the generators with an hour meter to record hours of operation. Any increase in hours of operation must be approved by the Department and may require a demonstration of compliance with state or federal ambient air standard. Reports of the hours of operation shall be submitted annually. This is a State Only requirement.

#### RECORD OF REVISIONS

Revision Date	Description of Change
4/01/2014	Updated template and removed Exempt Source list.
02-06-2015	Updated ATTACHMENT - Emission Rates for Ambient Air Standards
01-21-2016	Generator capacities listed in previous permit was incorrect and have been revised. The facility has indicated they will not operate either generators more than 500 hr/yr to be exempt from modeling. Attachment for Ambient Air Standards have been removed and modeling avoidance condition is being added with this revision. Exempt source list added back to the attachment.