

ATTACHMENT - Facility Information

**South Island Public Service District
GCM-0360-0051
Page 1 of 1**

GENERAL INFORMATION

A - APPLICABLE PERMIT DATES

COVERAGE DATE: April 1, 2011

B - FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 2 Lawton Canal Road
CITY, STATE, ZIP FACILITY IS LOCATED IN: Hilton Head Island, South Carolina 29928
COUNTY FACILITY IS LOCATED IN: Beaufort

C - EQUIPMENT INSTALLED

Equipment ID	Equipment Description	Fuels Used	Installation Date	Modification Date	Emission Point ID
GEN04	1500 kW Generator used for emergency and non-emergency (peak shaving)	No. 2 Fuel Oil (≤0.05% sulfur)	2003	None	1

D- ADDITIONAL CONDITIONS - RESERVED

RECORD OF REVISIONS FOR GCM-0360-0051	
Revision Date	Description of Change
04-01-2014	Updated template and removed exempt source list
10-10-2014	Corrected Coverage date from March 20, 2011 to April 1, 2011
02-06-2015	Updated ATTACHMENT - Emission Rates for Ambient Air Standards

ATTACHMENT - Emission Rates for Ambient Air Standards

South Island Public Service District

GCM-0360-0051

Page 1 OF 1

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2					
Emission Point ID	Emission Rates (lbs/hr)				
	PM ₁₀	PM _{2.5}	SO ₂	NO _x	CO
1	0.7540	---	0.7427	33.9841	11.4762