

ATTACHMENT - Facility Information

**Beaufort-Jasper Water & Sewer Authority – Port Royal WWRF
GCM-0360-0070
Page 1 of 1**

APPLICABLE PERMIT DATES

COVERAGE DATE: November 17, 2014

FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 285 Castle Rock Road
CITY, STATE, ZIP FACILITY IS LOCATED IN: Burton, SC 29906
COUNTY FACILITY IS LOCATED IN: Beaufort

EQUIPMENT INSTALLED

Equipment ID	Equipment Description	Fuels Used	Installation Date	Emission Point ID
PRDG1	2885 HP, 2000 kWe Peak Shaving Generator	Diesel with sulfur content equal to or less than 0.05%	2006	PRDG1

RECORD OF REVISIONS	
Revision Date	Description of Change
02-06-2015	Updated Attachment Emission Rates for Ambient Air Standards

ATTACHMENT - Emission Rates for Ambient Air Standards

**Beaufort-Jasper Water & Sewer Authority – Port Royal WWRF
GCM-0360-0070
Page 1 OF 1**

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

AMBIENT AIR QUALITY STANDARDS - STANDARD 2				
Emission Point ID	Emission Rates (lbs/hr)			
	PM₁₀	SO₂	NO_x	CO
PRDG1	1.94	0.98	62.2	16.52