



W. Marshall Taylor Jr., Acting Director

*Promoting and protecting the health of the public and the environment*

April 30, 2015

Fred Edgar  
Roper St. Francis Mount Pleasant Hospital  
3500 Hwy 17 North  
Mount Pleasant, SC 29466

RE: Air Quality Registration Permit for Fuel Combustion Operations  
Permit Number: 0560-0413

Enclosed is an Air Quality Registration Permit for Fuel Combustion Operations ("Registration Permit") issued on August 1, 2011. Please note the conditions, emissions limitations, and operational requirements contained within this permit. This permit supersedes any previous construction and/or operating permits that were issued to your facility. Your facility's coverage under the terms and conditions of this permit shall be effective on April 30, 2015. This letter should be retained with the registration permit.

It is your responsibility to comply with all the requirements of this Registration Permit. The Department may conduct periodic inspections of your facility to determine compliance with the requirements of the Registration Permit. Any violations found during these inspections may result in an enforcement action. Therefore, it is incumbent upon you to ensure you are in compliance with the Registration Permit at all times. It is important for you to read this issued permit carefully and to understand all requirements. If any errors or omissions are found, immediately notify Hetal Patel of my staff, via email at [patelhy@dhec.sc.gov](mailto:patelhy@dhec.sc.gov), or call (803) 898-3850.

In the event, you disagree with the decision to approve the Registration Permit, or the terms and conditions of the Registration Permit, the enclosed "Guide to Board Review" explains the process for contesting the Department's decision.

Sincerely,

Elizabeth J. Basil  
Director, Engineering Services Division  
Bureau of Air Quality

EJB:hyp/kal:kal

Enclosure

cc: Registration Permit File: 0560-0413

ec: Wendy Boswell, BEHS  
Cindy Kilpatrick, Technical Management Section  
Elisa Vincent, Emissions Inventory Section

## Additional Approved Fuels

### Air Quality Registration Permit for Fuel Combustion Operations

**Roper St. Francis Mount Pleasant Hospital**

**0560-0413**

**Page 1 of 1**

In addition to the fuels allowed under the Registration Permit for Fuel Combustion Operations, Roper St. Francis Mount Pleasant Hospital is allowed to burn the following:

<b>Equipment Description</b>	<b>Additional Fuels Approved For Use</b>	<b>Restrictions</b>
3.5 million BTU/hr boiler	No. 2 fuel oil (Sulfur content shall be less than or equal to 0.5% by weight)	None
3.5 million BTU/hr boiler	No. 2 fuel oil (Sulfur content shall be less than or equal to 0.5% by weight)	