



W. Marshall Taylor Jr., Acting Director

Promoting and protecting the health of the public and the environment

May 14, 2015

Ian Clugston
McLeod Medical Center – Dillon
301 East Jackson St.
Dillon, SC 29536

RE: Air Quality Registration Permit for Fuel Combustion Operations
Permit Number: 0880-0025

Enclosed is an Air Quality Registration Permit for Fuel Combustion Operations (“Registration Permit”) issued on August 1, 2011. Please note the conditions, emissions limitations, and operational requirements contained within this permit. This permit supersedes any previous construction and/or operating permits that were issued to your facility. Your facility’s coverage under the terms and conditions of this permit shall be effective on May 14, 2015. This letter should be retained with the registration permit.

It is your responsibility to comply with all the requirements of this Registration Permit. The Department may conduct periodic inspections of your facility to determine compliance with the requirements of the Registration Permit. Any violations found during these inspections may result in an enforcement action. Therefore, it is incumbent upon you to ensure you are in compliance with the Registration Permit at all times. It is important for you to read this issued permit carefully and to understand all requirements. If any errors or omissions are found, immediately notify Hetal Patel of my staff, via email at patelhy@dhec.sc.gov, or call (803) 898-3850.

In the event, you disagree with the decision to approve the Registration Permit, or the terms and conditions of the Registration Permit, the enclosed "Guide to Board Review" explains the process for contesting the Department's decision.

Sincerely,

Elizabeth J. Basil
Director, Engineering Services Division
Bureau of Air Quality

EJB:kal/hyp:kal

Enclosure

cc: Registration Permit File: 0880-0025

ec: Bryan Baxley, BEHS
Dawn Jordan, Technical Management Section
Elisa Vincent, Emissions Inventory Section

Additional Approved Fuels

Air Quality Registration Permit for Fuel Combustion Operations

McLeod Medical Center - Dillon

0880-0025

Page 1 of 1

In addition to the fuels allowed under the Registration Permit for Fuel Combustion Operations, McLeod Medical Center - Dillon is allowed to burn the following:

Equipment Description	Additional Fuels Approved For Use	Restrictions
8.16 million BTU/hr boiler	No. 2 fuel oil (Sulfur content shall be less than or equal to 0.5% by weight)	--
8.16 million BTU/hr boiler	No. 2 fuel oil (Sulfur content shall be less than or equal to 0.5% by weight)	
2.51 million BTU/hr boiler	No. 2 fuel oil (Sulfur content shall be less than or equal to 0.5% by weight)	