

ATTACHMENT - Facility Information

Greenville Water GCM-1200-0334 Page 1 of 1

GENERAL INFORMATION

A - APPLICABLE PERMIT DATES

COVERAGE DATE: November 1, 2012

B - FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 50 Pleasant Retreat Road
CITY, STATE, ZIP FACILITY IS LOCATED IN: Travelers Rest, SC
COUNTY FACILITY IS LOCATED IN: Greenville

C - EQUIPMENT INSTALLED

Equipment ID	Equipment Description	Fuels Used	Installation Date	Modification Date	Emission Point ID
EG-601	1,825 kW Caterpillar generator (model #3516)	Diesel	1998	N/A	EG-601
EG-602	1,825 kW Caterpillar generator (model # 3516)	Diesel	1998	N/A	EG-602

D – ADDITIONAL CONDITIONS – RESERVED

RECORD OF REVISIONS FOR GCM-1200-0334	
Revision Date	Description of Change
04-01-2014	Updated template and removed exempt source list
10-10-2014	Corrected Coverage date from March 30, 2011 to November 1, 2012
02-06-2015	Updated ATTACHMENT - Emissions Rates for Ambient Air Standards

ATTACHMENT – Emission Rates for Ambient Air Standards

**Greenville Water
GCM-1200-0334
Page 1 OF 1**

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2							
Emission Point ID	Emission Rates (lbs/hr)						
	PM₁₀	PM_{2.5}	SO₂	NO_x	CO	Lead	Gaseous Fluorides (as HF)
EG-601	0.49	---	0.857	81.8	10.46	---	---
EG-602	0.49	---	0.857	81.8	10.46	---	---