

ATTACHMENT - Facility Information

Self Regional Healthcare

GCM-1240-0028

Page 1 of 1

GENERAL INFORMATION

A - APPLICABLE PERMIT DATES

COVERAGE DATE: April 1, 2011

B - FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 1325 Spring Street
CITY, STATE, ZIP FACILITY IS LOCATED IN: Greenwood, SC 29646-3875
COUNTY FACILITY IS LOCATED IN: Greenwood

C - EQUIPMENT INSTALLED

Equipment ID	Equipment Description	Fuels Used	Installation Date	Modification Date	Emission Point ID
B1	38.0 million BTU/hr B&W Boiler	Natural Gas No. 2 Fuel Oil (0.05% sulfur)	1977	N/A	EP01
B2	38.0 million BTU/hr B&W Boiler	Natural Gas No. 2 Fuel Oil (0.05% sulfur)	1977	N/A	EP02
E06	Ethylene Oxide Sterilizer	None	2006	N/A	N/A

D - ADDITIONAL CONDITIONS - RESERVED

RECORD OF REVISIONS FOR GCM-1240-0028	
Revision Date	Description of Change
04-01-2014	Updated template and removed exempt source list
10-10-2014	Corrected Coverage Date from March 30, 2011 to April 1, 2011
02-06-2015	Updated ATTACHMENT - Emission Rates for Air Ambient Standards

ATTACHMENT - Emission Rates for Ambient Air Standards

**Self Regional Healthcare
GCM-1240-0028
Page 1 OF 1**

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2							
Emission Point ID	Emission Rates (lbs/hr)						
	PM₁₀	PM_{2.5}	SO₂	NO_x	CO	Lead	Gaseous Fluorides (as HF)
Boiler #1	0.8957	0.8957	--	--	3.1920	--	--
Boiler #2	0.8957	0.8957	--	--	3.1920	--	--
Boiler #4	0.0137	0.0137	0.4100	0.0810	0.0680	--	--

TOXIC AIR POLLUTANTS - STANDARD NO. 8		
POLLUTANT	CAS NUMBER	Facility Wide Emission Rates (lbs/day)
Ethylene Oxide	75-21-8	0.0182