

ATTACHMENT - Facility Information

Beaufort-Jasper Water & Sewer Authority - Purrysburg WTP

GCM-1360-0042

Page 1 of 1

APPLICABLE PERMIT DATES

COVERAGE DATE: November 17, 2014

FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 10314 Purrysburg Road
 CITY, STATE, ZIP FACILITY IS LOCATED IN: Hardeeville, SC 29927
 COUNTY FACILITY IS LOCATED IN: Jasper

Equipment ID	Equipment Description	Fuels Used	Installation Date	Emission Point ID
PDG1	2394 kW Peak Shaving Generator	Diesel with sulfur content equal to or less than 0.05%	2004	PDG1

EXEMPT SOURCES

Equipment ID	Equipment Description	Installation Date	Modification Date	Basis
CA-ST1	1800 gallon diesel fuel oil storage tank	2004	N/A	SC Regulation 61-62.1 Section II(B)(2)(h)

ADDITIONAL CONDITIONS

The owner or operator must comply with the conditions of the General Conditional Major Operating Permit for Fuel Combustion Operations and any additional conditions listed in this section.

Condition Number	Conditions
1.	The generator is limited to 500 hr/yr operation in order to be exempt from demonstrating compliance through air dispersion modeling or other method the facility's operations will not interfere with the attainment and maintenance of any state or federal ambient air standard. The owner/operator must equip the generator with an hour meter to record hours of operation. Any increase in hours of operation must be approved by the Department and may require a demonstration of compliance with state or federal ambient air standard. Reports of the hours of operation shall be submitted annually. This is a State Only requirement.

RECORD OF REVISIONS

Revision Date	Description of Change
12-01-2014	Correct facility physical address.
02-06-2015	Updated ATTACHMENT - Emission Rates for Ambient Air Standards
01-21-2016	Updated generator capacity from 2200 kW to 2394 kW. Added emodeling exemption condition and exempt sources table. Removed ambient air standards table.