

ATTACHMENT - Facility Information

SOPAKCO Inc.
GCM-1680-0104
Page 1 of 1

GENERAL INFORMATION

A - APPLICABLE PERMIT DATES

COVERAGE DATE: April 1, 2011

B - FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 320 South Broad Street
CITY, STATE, ZIP FACILITY IS LOCATED IN: Bennettsville, SC 29512
COUNTY FACILITY IS LOCATED IN: Marlboro

C - EQUIPMENT INSTALLED

Equipment ID	Equipment Description	Fuels Used	Installation Date	Modification Date	Emission Point ID
Boiler #1	26 million BTU/hr Hurst 600 Series Boiler NSPS A and Dc	Natural gas No. 2 Fuel Oil ($\leq 0.5\%$ sulfur)	10-16-2001	02-01-2006 (added Low NO _x burners)	Boiler 1
Boiler #2	26 million BTU/hr Johnson 600 Boiler NSPS A and Dc	Natural gas No. 2 Fuel Oil ($\leq 0.5\%$ sulfur)	03-04-1996	10-16-2001	Boiler 2

D- ADDITIONAL CONDITIONS – RESERVED

RECORD OF REVISIONS FOR GCM-1680-0104	
Revision Date	Description of Change
04-01-2014	Updated Template and Removed Exempt Source List
10-10-2014	Corrected Coverage Date from March 30, 2011 to April 1, 2011
02-06-2015	Updated Attachment - Emission Rates for Ambient Air Standards

ATTACHMENT - Emission Rates for Ambient Air Standards

**SOPAKCO Inc.
GCM-1680-0104
Page 1 OF 1**

The emission rates listed herein are not considered enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2				
Emission Point ID	Emission Rates (lbs/hr)			
	PM₁₀	SO₂	NO₂	CO
Boiler 1	0.63	13.20	3.96	2.38
Boiler 2	0.63	13.20	3.96	2.38