

## ATTACHMENT - Facility Information

### City of Seneca/Seneca Light & Water GCM-1820-0072 Page 1 of 1

#### APPLICABLE PERMIT DATES

COVERAGE DATE: August 10, 2015

#### FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 219 Goddard Avenue  
CITY, STATE, ZIP FACILITY IS LOCATED IN: Seneca, SC 29672  
COUNTY FACILITY IS LOCATED IN: Oconee

Equipment ID	Equipment Description	Fuels Used	Installation Date	Emission Point ID
Peak-shaving generator 1	1825kW Detroit Model 16V4000 generator	Diesel with sulfur content equal to or less than 0.05%	April 2004	Diesel Generators
Peak-shaving generator 2	1825kW Detroit Model 16V4000 generator	Diesel with sulfur content equal to or less than 0.05%	April 2004	Diesel Generators
Peak-shaving generator 3	1825kW Detroit Model 16V4000 generator	Diesel with sulfur content equal to or less than 0.05%	April 2004	Diesel Generators

#### ADDITIONAL CONDITIONS

The owner or operator must comply with the conditions of the General Conditional Major Operating Permit for Fuel Combustion Operations and any additional conditions listed in this section.

Condition Number	Conditions
1.	Each generator is limited to 250 hours/year operation in order to comply with S.C. Regulation 61-62.5, Standard No. 2. The owner/operator must record actual hours of operation monthly. Any increase in allowable emission rate must be approved by the Department and may require re-modeling to demonstrate compliance with the above listed standard. Reports of the hours of operation shall be submitted annually. This is a State Only requirement.

#### RECORD OF REVISIONS

Revision Date	Description of Change

**ATTACHMENT - Emission Rates for Ambient Air Standards**

**City of Seneca/Seneca Light & Water  
GCM-1820-0072  
Page 1 OF 1**

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

<b>AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2</b>						
<b>Emission Point ID</b>	<b>Emission Rates (lbs/hr)</b>					
	<b>PM<sub>10</sub></b>	<b>PM<sub>2.5</sub></b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO</b>	<b>Lead</b>
Diesel Generators	0.049	--	0.124	6.734	0.350	--