

## ATTACHMENT - Facility Information

### SC Office of General Services FM Energy Facility GCM-1900-0162 Page 1 of 1

#### GENERAL INFORMATION

##### A - APPLICABLE PERMIT DATES

COVERAGE DATE: April 1, 2011

##### B - FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 1121 College St.  
CITY, STATE, ZIP FACILITY IS LOCATED IN: Columbia, SC 29201  
COUNTY FACILITY IS LOCATED IN: Richland

##### C - EQUIPMENT INSTALLED

| Equipment ID | Equipment Description   | Fuels Used   | Installation Date | Modification Date | Emission Point ID |
|--------------|---|--|-------------------|-------------------|-------------------|
| Boiler #1    | 33.5 million BTU/Hr. Cleaver Brooks CB1200800150 Fire Tube Boiler.<br>NSPS A and Dc | Natural gas<br>No. 2 Fuel Oil ( $\leq 0.5\%$ sulfur) | 12-2000           | None              | Boiler 1          |
| Boiler #3    | 25.1 million BTU/Hr. Cleaver Brooks CB428-600 Fire Tube Boiler<br>NSPS A and Dc     | Natural gas<br>No. 2 Fuel Oil ( $\leq 0.5\%$ sulfur) | 12-2002           | None              | Boiler 3          |

##### D – ADDITIONAL CONDITIONS – RESERVED

| RECORD OF REVISIONS FOR GCM-1900-0162 |   |
|---------------------------------------|---|
| Revision Date                         | Description of Change   |
| 04-01-2014                            | Updated template and exempt source list                       |
| 10-10-2014                            | Corrected Coverage Date from March 30, 2011 to April 1, 2011  |
| 02-06-2015                            | Updated ATTACHMENT - Emission Rates for Ambient Air Standards |

**ATTACHMENT – Emission Rates for Ambient Air Standards**

**SC Office of General Services FM Energy Facility  
GCM-1900-0162  
Page 1 OF 1**

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

| <b>AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2</b> |                                |                       |                       |           |
|---|--------------------------------|-----------------------|-----------------------|-----------|
| <b>Emission Point ID</b>                              | <b>Emission Rates (lbs/hr)</b> |                       |                       |           |
|   | <b>PM<sub>10</sub></b>         | <b>SO<sub>2</sub></b> | <b>NO<sub>2</sub></b> | <b>CO</b> |
| Boiler 1  | 0.6509                         | 16.989                | 1.786                 | 1.196     |
| Boiler 2  | 0.604                          | 12.93                 | 6.23                  | 3.77      |