

ATTACHMENT - Facility Information

**Sysco Food Services of Columbia, LLC
GCM-1900-0279
Page 1 of 1**

APPLICABLE PERMIT DATES

COVERAGE DATE: June 4, 2015

FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 131 Sysco Court
CITY, STATE, ZIP FACILITY IS LOCATED IN: Columbia, SC 29209
COUNTY FACILITY IS LOCATED IN: Richland

Equipment ID	Equipment Description	Control Devices	Fuels Used	Installation Date	Emission Point ID
GEN-1	1750 kW Peak Shaving Generator	Diesel Oxidizing Catalyst (DOC-1)	Ultra Low Sulfur Diesel	2001	EP-1

ADDITIONAL CONDITIONS

The owner or operator must comply with the conditions of the General Conditional Major Operating Permit for Fuel Combustion Operations and any additional conditions listed in this section.

Condition Number	Conditions
1.	The generator is limited to 500 hr/yr in order to be exempt from demonstrating compliance through air dispersion modeling or other method the facility's operations will not interfere with the attainment and maintenance of any state or federal ambient air standard. The owner/operator must equip the generator with an hour meter to record hours of operation. Any increase in hours of operation must be approved by the Department and may require a demonstration of compliance with state or federal ambient air standard. Reports of the hours of operation shall be submitted annually. This is a State Only requirement.

RECORD OF REVISIONS	
Revision Date	Description of Change

ATTACHMENT - Emission Rates for Ambient Air Standards

**Sysco Food Services of Columbia, LLC
GCM-1900-0279
Page 1 OF 1**

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2							
Emission Point ID	Emission Rates (lbs/hr)						
	PM₁₀	PM_{2.5}	SO₂	NO_x	CO	Lead	Gaseous Fluorides (as HF)
EP-1	1.87	1.87	0.03	64	14.67	0.00017	--