

**ATTACHMENT - Facility Information**

**Spartanburg Hospital for Restorative Care**

**GCM-2060-0128**

**PAGE 1 OF 1**

**GENERAL INFORMATION**

**A - APPLICABLE PERMIT DATES**

COVERAGE DATE: April 1, 2011

**B - FACILITY PHYSICAL ADDRESS**

FACILITY STREET ADDRESS: 389 Serpentine Drive  
 CITY, STATE, ZIP FACILITY IS LOCATED IN: Spartanburg, SC 29303  
 COUNTY FACILITY IS LOCATED IN: Spartanburg

**C - EQUIPMENT INSTALLED**

Equipment ID	Equipment Description	Fuels Used	Installation Date	Modification Date	Emission Point ID
Boiler #1	3.17 million Btu/hr for natural gas 3.08 million BTU/hr for No. 2 fuel oil Peerless Boiler (model TC-10-W/S)	Natural Gas No. 2 Fuel Oil (≤0.5% sulfur content)	2005	None	Boiler #1
Boiler #2	3.17 million Btu/hr for natural gas 3.08 million BTU/hr for No. 2 fuel oil Peerless Boiler (model TC-10-W/S)	Natural Gas No. 2 Fuel Oil (≤0.5% sulfur content)	2005	None	Boiler #2

**D – ADDITIONAL CONDITIONS**

The owner/operator must comply with the conditions of the General Conditional Major Operating Permit for Fuel Combustion Operations and any additional conditions listed in this section.

Condition Number	Conditions
D.1	Spartanburg Hospital for Restorative Care (2060-0128) and Spartanburg Regional Medical Center (2060-0142) are considered to be co-located. Combined emissions from both Spartanburg for Restorative Care and Spartanburg Regional Medical Center facilities shall be used to determine compliance with the facility wide emission limits established under the General Conditional Major Operating Permit for Fuel Combustion Operations.  No record keeping is required for Spartanburg Hospital for Restorative Care (2060-0128). The limitations taken by Spartanburg Regional Medical Center (2060-0142) will ensure both facilities remain below all thresholds.

**RECORD OF REVISIONS FOR GCM-2060-0128**

Revision Date	Description of Change
04-01-2014	Updated template and removed exempt source list
10-10-2014	Corrected Coverage Date from March 30, 2011 to April 1, 2011
02-06-2015	Updated ATTACHMENT - Emission Rates for Ambient Air Standards

**ATTACHMENT - Emission Rates for Ambient Air Standards**

**Spartanburg Hospital for Restorative Care**

**GCM-2060-0128**

**PAGE 1 OF 1**

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

<b>AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2</b>					
<b>Emission Point ID</b>	<b>Emission Rates (lbs/hr)</b>				
	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO</b>
SHRC B-1-Boiler 1	0.0730	0.0520	1.5619	0.4399	0.1100
SHRC B-2 Boiler 2	0.0730	0.0520	1.5619	0.4399	0.1100