

ATTACHMENT - Facility Information

Inman Mills – Ramey Plant GCM-2060-0271

Page 1 of 1

A - APPLICABLE PERMIT DATES

COVERAGE DATE: May 6, 2014

B - FACILITY PHYSICAL ADDRESS

STREET ADDRESS: 15980 Hwy 221
CITY, STATE, ZIP: Enoree, SC 29335
COUNTY: Spartanburg

C - EMISSION UNIT DESCRIPTION

Emission Unit ID	Emission Unit Description
01	Boilers
02	Slashers

D - EQUIPMENT AND CONTROL DEVICES

D.1 - EQUIPMENT FOR EMISSION UNIT 01 - BOILERS

Equipment ID	Equipment Description	Installation Date/Modification Date	Control Device ID	Emission Point ID
Boiler #1	29.29 million BTU/hr Brooks boiler fired on Natural Gas and No. 2 and No. 6 Fuel Oil (0.5% sulfur content by weight) as back up	1995	N/A	BS1
Boiler #2	29.29 million BTU/hr Brooks boiler fired on Natural Gas and No. 2 and No. 6 Fuel Oil (0.5% sulfur content by weight) as back up	1/27/1996	N/A	BS2
Boiler #3	29.29 million BTU/hr Brooks boiler fired on Natural Gas and No. 2 and No. 6 Fuel Oil (0.5% sulfur content by weight) as back up	4/3/1996	N/A	BS3

D.2 - EQUIPMENT FOR EMISSION UNIT 02 – SLASHERS

Equipment ID	Equipment Description	Installation Date/Modification Date	Control Device ID	Emission Point ID
Slasher #1	Slasher (PVA/Starch with a maximum methanol content of 0.1%)	1966	N/A	SS1
Slasher #2	Slasher (PVA/Starch with a maximum methanol content of 0.1%)	1966	N/A	SS2
Slasher #3	Slasher (PVA/Starch with a maximum methanol content of 0.1%)	1995	N/A	SS3
Slasher #4	Slasher (PVA/Starch with a maximum methanol content of 0.1%)	1995	N/A	SS4
Slasher #5	Slasher (PVA/Starch with a maximum methanol content of 0.1%)	1995	N/A	SS5

E - RESERVED

RECORD OF REVISIONS	
Revision Date	Description of Change
1-29-2015	Updated Attachment Emission Rates for Ambient Air Standards

ATTACHMENT - Emission Rates for Ambient Air Standards

**Inman Mills – Ramey Plant
GCM-2060-0271**

Page 1 of 1

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards.

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2							
Emission Point ID	Emission Rates (lbs/hr)						
	PM₁₀	PM_{2.5}	SO₂	NO_x	CO	Lead	Gaseous Fluorides (as HF)
Boiler 1	1.526	--	15.325	10.737	0.976	--	--
Boiler 2	1.526	--	15.325	10.737	0.976	--	--
Boiler 3	1.526	--	15.325	10.737	0.976	--	--

TOXIC AIR POLLUTANTS - STANDARD NO. 8		
POLLUTANT	CAS NUMBER	Facility Wide Emission Rates (lbs/day)
Methanol	67-56-1	11.4