

ATTACHMENT - Facility Information

R.B. Simms Filtration Plant GCM-2060-0334 Page 1 of 1

GENERAL INFORMATION

A - APPLICABLE PERMIT DATES

COVERAGE DATE: January 1, 2012

B - FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 390 Spartanburg Water Works Road
CITY, STATE, ZIP FACILITY IS LOCATED IN: Chesnee, SC 29323-8607
COUNTY FACILITY IS LOCATED IN: Spartanburg

C - EQUIPMENT INSTALLED

Equipment ID	Equipment Description	Fuels Used	Installation Date	Modification Date	Emission Point ID
G-1	2,000 kW Diesel Generator (emergency and peak shaving), model Cummins 2000DQKAB	Diesel Fuel (maximum sulfur content 0.0015% or less)	12/2/2011	None	S-G1

D - ADDITIONAL CONDITIONS

The owner/operator must comply with the conditions of the General Conditional Major Operating Permit for Fuel Combustion Operations and any additional conditions listed in this section.

Condition Number	Conditions
D.1	In order to demonstrate compliance with S.C. Regulation 61-62.5, Standard No. 2 and Standard No. 7, G-1 is limited to operating a maximum of 3,500 hours per year. The owner/operator must record the actual operating hours and submit reports of the recorded hours of operation as outlined in outlined in the General Conditional Major Operating Permit for Fuel Combustion Operations.

RECORD OF REVISIONS FOR GCM-2060-0334

Revision Date	Description of Change
04-01-2014	Updated template and removed exempt source list
10-02-2014	Removed Unit ID G-2 Equipment ID 1,250 kW Diesel Generator, model Cumings/Onan 1250DFLG to the exempt source list. Removed Conditions D.1 and D.3. Corrected coverage date to January 1, 2012.
02-06-2015	Updated ATTACHMENT - Emission Rates for Ambient Air Standards

ATTACHMENT - Emission Rates for Ambient Air Standards

**R. M. Simms Filtration Plant
GCM-2060-0334
Page 1 OF 1**

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2					
Emission Point ID	Emission Rates (lbs/hr)				
	PM₁₀	PM_{2.5}	SO₂	NO_x	CO
S-G1	0.45	0.41	0.71	13.62	1.16
S-G2A	0.145	0.13	1.205	4.433	2.04
S-G2B	0.145	0.13	1.205	4.433	2.04