

# ATTACHMENT - Facility Information

## Utility Operation Center GCM-2440-0207 Page 1 of 1

### APPLICABLE PERMIT DATES

COVERAGE DATE: September 2, 2011

### FACILITY PHYSICAL ADDRESS

FACILITY STREET ADDRESS: 727 S. Anderson Road  
CITY, STATE, ZIP FACILITY IS LOCATED IN: Rock Hill, SC 29730  
COUNTY FACILITY IS LOCATED IN: York

Equipment ID	Equipment Description	Control Devices	Fuels Used	Installation Date	Emission Point ID
ENG-1	1500 kW Cummins Generator (emergency and peak shaving power)	Oxidation Catalyst Silencer No.1 (OC-1)	No. 2 Diesel Fuel (<0.05% sulfur by weight)	7/28/2011	DG-1
ENG-2	1500 kW Cummins Generator (emergency and peak shaving power)	Oxidation Catalyst Silencer No.2 (OC-2)	No. 2 Diesel Fuel (<0.05% sulfur by weight)	7/28/2011	DG-2

### ADDITIONAL CONDITIONS

The owner or operator must comply with the conditions of the General Conditional Major Operating Permit for Fuel Combustion Operations and any additional conditions listed in this section.

Condition Number	Conditions
1.	In accordance with SC Regulation 61-62.5, Standard No. 2, Ambient Air Quality Standards, the generators are limited to operating a maximum of 500 hours per year per generator. The owner/operator must record the actual operating hours and submit reports of the recorded hours of operation as outlined in the General Conditional Major Operating Permit for Fuel Combustion Operations.

RECORD OF REVISIONS	
Revision Date	Description of Change
4-01-2014	Updated template and removed exempt source list
12-02-2014	Corrected Coverage Date from March 30, 2011 to September 2, 2011
02-06-2015	Updated ATTACHMENT - Emission Rates for Ambient Air Standards
06-24-2016	Removed Source Testing Condition D.2

# ATTACHMENT - Emission Rates for Ambient Air Standards

## Utility Operation Center GCM-2440-0207 Page 1 OF 1

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards (see Ambient Air Standards Requirements).

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2						
Emission Point ID	Emission Rates (lbs/hr)					
	PM <sub>10</sub>	PM <sub>2.5</sub>	SO <sub>2</sub>	NO <sub>x</sub>	CO	Lead
DG-1 & DG-2	1.457	1.407	1.261	56.272	9.314	---