



# ATTACHMENT A

## Facility Information

**Columbia Farms Inc. Greenville**

**GCM-1200-0232**

**Page 2 of 3**

### D - EQUIPMENT INSTALLED

Equipment ID	Equipment Description	Control Devices	Fuels Used	Installation Date	Modification Date	Emission Point ID
Boiler #1	14.7 million BTU/hr Cleaver Brooks, Model CB-400-350, Boiler	None	Natural gas No. 2 Fuel Oil (≤0.5% sulfur content by weight) No. 4, 6 Fuel Oil (≤2.1% sulfur content by weight)	03-08-1993	None	Boiler 1

### F - EXEMPT SOURCES

Equipment ID	Equipment Description	Installation Date	Modification Date	Basis
EX-WH	72,000 BTU/hr Natural Gas Fired Hot Water Heater	07-25-1997	None	SC Regulation 61-62.1, Section II(B)(2)(a)
EX-Heater	(2) 40,000 BTU/hr Propane Fired Space Heaters	04-07-2006	None	SC Regulation 61-62.1, Section II(B)(2)(a)
EX-Tank 1	4,500 Gallon No. 2 Fuel Oil Storage Tank	05-16-2001	None	SC Regulation 61-62.1, Section II(B)(2)(h)
EX-Tank 2	1000 Gallon Diesel (No. 2 Fuel Oil) Storage Tank	07-25-1997	None	SC Regulation 61-62.1, Section II(B)(2)(h)
EX-PW	Parts Washer	05-17-2001	None	SC Regulation 61-62.1, Section II(B)(2)(h)
EX-AARS	Anhydrous Ammonia Refrigeration System	01-17-2007	None	SC Regulation 61-62.1, Section II(B)(2)(h)
EX-CO2 Tank	15 Ton Carbon Dioxide Tank	04-2009	None	SC Regulation 61-62.1, Section II(B)(2)(g)
EX-CO2FE	Carbon Dioxide Fire Extinguishers	05-18-2001	None	SC Regulation 61-62.1, Section II(B)(2)(g)
EX-CO2 Cylinders	Carbon Dioxide Cylinders	04-12-2006	None	SC Regulation 61-62.1, Section II(B)(2)(g)

### G - CONDITIONS

Condition Number	Equipment/Control Device ID	Regulated Pollutant/Standard	Conditions
G.1	Facility Wide	112r	<p>It has been determined that this facility is subject to SC Regulation 61-62.68, Chemical Accident Prevention Provisions, due to in-process storage or use of a regulated substance in quantities above the specified threshold and that a Risk Management Plan (RMP) has already been submitted to the EPA; therefore, the following must be completed:</p> <ol style="list-style-type: none"> <li>1. Submittal of subsequent revisions/corrections/updates of the RMP in accordance with SC Regulation 61-62.68.190 and 68.195.</li> </ol>

**ATTACHMENT A**

**Facility Information**

**Columbia Farms Inc. Greenville**

**GCM-1200-0232**

**Page 3 of 3**

**G - CONDITIONS**

<b>Condition Number</b>	<b>Equipment/ Control Device ID</b>	<b>Regulated Pollutant/ Standard</b>	<b>Conditions</b>
			<p>2. If it is determined by the Department that additional relevant information is needed, this facility will be required to submit the information in a timely manner.</p> <p>For Program 1 processes, the owner or operator shall submit along with the RMP the certification statement provided in Section 68.12(b)(4). For all other covered processes, the owner or operator shall submit along with the RMP a single certification that, to the best of the signer's knowledge, information, and belief formed after reasonable inquiry, the information submitted is true, accurate, and complete.</p>

# ATTACHMENT B

## Modeled Emission Rates

Columbia Farms Inc. Greenville

GCM-1200-0232

Page 1 OF 1

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards.

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2				
Emission Point ID	Modeled Emission Rates (lbs/hr)			
	PM <sub>10</sub>	SO <sub>2</sub>	NO <sub>2</sub>	CO
Boiler 1	1.9	32.0	6.5	0.5

March 30, 2011

Mr. Mike Jones  
Columbia Farms Inc. Greenville  
1354 Rutherford Rd.  
Greenville, SC 29608

Re: Renewal of Coverage to Operate Under the Terms and Conditions of the General Conditional Major Operating Permit for Fuel Combustion Operations No. GCM-1200-0232 for Columbia Farms Inc. Greenville at 1354 Rutherford Rd., Greenville, SC 29609.

Dear Mr. Jones:

Enclosed is a renewed General Conditional Major Operating Permit for Fuel Combustion Operations No. GCM-1200-0232 that will become effective on April 01, 2011. The federally enforceable emissions limitations and operational requirements contained within this General Conditional Major Operating Permit are designed to restrict this facility's potential to emit to below major source thresholds. This renewed General Conditional Major Operating Permit will be valid through March 31, 2021.


Please be advised that reports required under the terms and conditions of this renewed Conditional Major Operating Permit must be completed and submitted in a timely manner in accordance with the periodic reporting schedule found in Part 4.B of this permit. The Department has developed an Excel spreadsheet that may help you in maintaining "Fuel Usage Records for General Conditional Major Operating Permit Reporting," which can be found at the following web site address:

[http://www.scdhec.gov/environment/baq/docs/permitting/GPermitApps/GCMP\\_Fuel\\_Worksheet.xls](http://www.scdhec.gov/environment/baq/docs/permitting/GPermitApps/GCMP_Fuel_Worksheet.xls)

It is important for you and/or an authorized representative responsible for the overall operation of this facility to read this issued permit carefully and to understand all requirements. If any errors or omissions are discovered, please notify Alyson M. Hayes of my staff, via e-mail at hayesam@dhec.sc.gov, or call 803-898-3836 immediately.

Pursuant to the South Carolina Administrative Procedures Act, any Department decision involving the issuance, denial, suspension, or revocation of a permit or certification may be appealed by the applicant, permittee, licensee, or affected person. Please see the enclosed "Notice of Appeal Procedure" for guidelines on filing an appeal.

Sincerely,



Elizabeth J. Basil  
Director, Engineering Services Division  
Bureau of Air Quality

EJB:amh:drc

Enclosure

cc: William H Williamson, Region 2, Greenville EQC Office  
Permit File: 1200-0232