

## Monthly Spill Bucket Inspection Log

- Use this form to record results of visual inspections of each spill bucket at the facility once each month.
- A separate form should be used for each facility. Indicate the year this form is for in the space provided.
- The front of this form has space for up to six spill buckets. If there are more than six spill buckets at this facility, use the back of this form or make additional copies.
- If no standing liquid or spill bucket defects (cracks, torn connectors, etc.) are noted, write “OK” in the appropriate column and row.
- If any standing liquid or spill bucket defects are noted, write “Not OK” in the appropriate column and indicate what action was taken.
- You must take measures to repair any spill bucket defects observed. If there are spill bucket defects and indications of released petroleum, it must be reported as a suspected release.
- Maintain the last 12 months of these inspections and have them available for state inspection.

### UST FACILITY INFORMATION

Name:	Facility ID #:	Year:
Address:	City:	Zip:

Date Checked	SB # 1	SB # 2	SB # 3	SB # 4	SB # 5	SB # 6	Action taken if SB not ok	Initials

