

September 13, 2011

Marion Moody
Beaufort County Memorial Hospital
955 S Ribaut Road
Beaufort, SC 29902

RE: Air Quality Registration Permit for Fuel Combustion Operations

Dear Moody:


Enclosed with this letter is a copy of the Air Quality Registration Permit for Fuel Combustion Operations issued on August 1, 2011. The Registration Permit for Fuel Combustion Operations allows for use of additional fuels with prior approval from the Bureau of Air Quality. Attached with this permit is an additional list of approved fuels. Please keep this attachment with your registration permit.

Please note the conditions, emissions limitations, and operational requirements contained within this permit. This permit will be valid through July 31, 2021 and supersedes any previous construction and/or operating permits that were issued to your facility. Your facility's coverage under the terms and conditions of this permit shall be effective on September 13, 2011.

It is important for you and/or an authorized representative responsible for the overall operation of this facility to read this issued permit carefully and to understand all requirements. If any errors or omissions are discovered, please notify Alyson Hayes of my staff, via e-mail at hayesam@dhec.sc.gov, or call (803) 898-3836 immediately.

Pursuant to the South Carolina Administrative Procedures Act, any Department decision involving the issuance, denial, suspension, or revocation of a permit or certification may be appealed by the applicant, permittee, licensee, or affected person. Please see the enclosed "Notice of Appeal Procedure" for guidelines on filing an appeal.

Sincerely,



Elizabeth J. Basil
Director, Engineering Services Division
Bureau of Air Quality

EJB:amh

Enclosure

cc: Registration Permit File: 0360-0049

ec: Shane L Johnson, Region 8, Beaufort EQC Office
Cindy Kilpatrick, Technical Management Section
Annie Richardson, Emissions Inventory

Additional Approved Fuels

Air Quality Registration Permit for Fuel Combustion Operations

Beaufort County Memorial Hospital

0360-0049

Page 1 of 1

In addition to the fuels allowed under the Registration Permit for Fuel Combustion Operations, Beaufort County Memorial Hospital is allowed to burn the following:

Equipment Description	Additional Fuels Approved For Use	Restrictions
4.184 million BTU/hr boiler	No. 5 fuel oil (Sulfur content shall be less than or equal to 1.27% by weight)	These boilers are not allowed to run simultaneously while burning No. 5 fuel oil.
3.35 million BTU/hr boiler	No. 5 fuel oil (Sulfur content shall be less than or equal to 1.27% by weight)	