

BOARD:
Allen Amsler
Chairman
Mark S. Lutz
Vice Chairman



Catherine B. Templeton, Director

Promoting and protecting the health of the public and the environment

BOARD:
R. Kenyon Wells
L. Clarence Batts, Jr.
Ann B. Kirol, DDS
John O. Hutto, Sr., MD

November 1, 2012

Mr. K.C. Price, P.E.
Director of Water Resources
Greenville Water
50 Pleasant Retreat Road
Travelers Rest, SC 29690

Re: Coverage to Operate Under the Terms and Conditions of the General Conditional Major Operating Permit for Fuel Combustion Operations

Dear Mr. Price:

Enclosed is the General Conditional Major Operating Permit for Fuel Combustion Operations that became effective on April 01, 2011. The federally enforceable emissions limitations and operational requirements contained within this General Conditional Major Operating Permit are designed to restrict this facility's potential to emit to below major source thresholds. This General Conditional Major Operating Permit will be valid through March 31, 2021. Your facility's coverage under the terms and conditions of this permit shall be effective on November 1, 2012.

Please be advised that a new periodic reporting period begins upon the effective date of this renewed permit. Abbreviated periodic reports shall be completed and submitted in accordance with the previous permit's conditions and shall cover the interim period between the previous permit reporting period and the renewed permit reporting period. Reports required under the terms and conditions of this renewed Conditional Major Operating Permit must be completed and submitted in a timely manner in accordance with the periodic reporting schedule found in Part 4.B of this permit. The Department has developed an Excel spreadsheet that may help you in maintaining "Fuel Usage Records for General Conditional Major Operating Permit Reporting," which can be found at the following web site address:

http://www.scdhec.gov/environment/baq/docs/permitting/GPermitApps/Fuel_Record_Reporting_Worksheet.xls

It is important for you and/or an authorized representative responsible for the overall operation of this facility to read this issued permit carefully and to understand all requirements. If any errors or omissions are discovered, please notify Charles P. Beam, P.E. of my staff, via e-mail at beamcp@dhec.sc.gov, or call 803-898-9524 immediately.

Pursuant to the South Carolina Administrative Procedures Act, any Department decision involving the issuance, denial, suspension, or revocation of a permit or certification may be appealed by the applicant, permittee, licensee, or affected person. Please see the enclosed "Notice of Appeal Procedure" for guidelines on filing an appeal.

Sincerely,

Elizabeth J. Basil
Director, Engineering Services Division
Bureau of Air Quality

EJB:cpb:kal

Enclosure

cc: Conditional Major File: 1200-0334
ec: Bill Williamson, Region 2, Greenville EQC Office

Notice of Appeal Procedure
Pursuant to S.C. Code Section 44-1-60

1. This decision of the S.C. Department of Health and Environmental Control (Department) becomes the final agency decision 15 calendar days after notice of the decision has been mailed or otherwise sent to the applicant, permittee, licensee and affected persons who have requested in writing to be notified, unless a written request for final review accompanied by a filing fee in the amount of \$100 is filed with the Department by the applicant, permittee, licensee, or affected person.
2. An applicant, permittee, licensee, or affected person who wishes to appeal this decision must file a timely written request for final review with the Clerk of the Board at the following address or by facsimile at 803-898-3393. A filing fee in the amount of \$100 made payable to SC DHEC must also be received by the Clerk within the time allowed for filing a request for final review. However, if a request for final review is filed by facsimile, the filing fee may be mailed to the Clerk of the Board if the envelope is postmarked within the time allowed for filing a request for final review.

Clerk of the Board
SC DHEC
2600 Bull Street
Columbia, SC 29201

3. In order to be timely, a request for final review must be received by the Clerk of the Board within 15 calendar days after notice of the decision has been mailed or otherwise sent to persons entitled to receive notice. If the 15th day occurs on a weekend or State holiday, the request is due to be received by the Clerk of the Board on the next working day. The request for final review must be received by the Clerk of the Board by 5:00 p.m. on the date it is due. A request for final review will be returned to the requestor if the filing fee is not received on time as described above.
4. The request for final review should include the following:
 - a. the grounds on which the Department's decision is challenged and the specific changes sought in the decision
 - b. a statement of any significant issues or factors the Board should consider in deciding whether to conduct a final review conference
 - c. a copy of the Department's decision for which review is requested
5. If a timely request for final review is filed with the Clerk of the Board, the Clerk will provide additional information regarding procedures. If the Board declines in writing to schedule a final review conference, the Department's decision becomes the final agency decision and an applicant, permittee, licensee, or affected person may request a contested case hearing before the Administrative Law Court within 30 calendar days after notice is mailed that the Board declined to hold a final review conference.

The above information is provided as a courtesy; parties are responsible for complying with all applicable legal requirements.

ATTACHMENT A

Facility Information

Greenville Water

GCM-1200-0334

Page 2 of 2

D - EQUIPMENT INSTALLED

Equipment ID	Equipment Description	Control Devices	Fuels Used	Installation Date	Modification Date	Emission Point ID
EG-601	1,825 kW Caterpillar generator (model #3516)	N/A	Diesel	1998	N/A	EG-601
EG-602	1,825 kW Caterpillar generator (model # 3516)	N/A	Diesel	1998	N/A	EG-602

E - EXEMPT SOURCES

Equipment ID	Equipment Description	Installation Date	Modification Date	Basis
A	One(1) 10,000 gallon capacity diesel storage tank	1990	May 21, 2002	SC Regulation 61-62.1 Section II B(2)(h)
B	51 propane-fired space heaters (total of 1.9 Million BTU/hr heat input capacity)	May 21, 2002	N/A	SC Regulation 61-62.1 Section II B(2)(h)

F - CONDITIONS

Condition Number	Equipment/ Control Device ID	Regulated Pollutant/ Standard	Conditions
N/A	N/A	N/A	N/A

ATTACHMENT B

Modeled Emission Rates

Greenville Water

GCM-1200-0334

Page 1 OF 1

The emission rates listed herein are not considered federally enforceable limitations but are used to evaluate ambient air quality impact. Until the Department makes a determination that a facility is causing or contributing to an exceedance of a state or federal ambient air quality standard, increases to these emission rates are not in themselves considered violations of these ambient air quality standards.

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2					
Emission Point ID	Modeled Emission Rates (lbs/hr)				
	PM	PM ₁₀	PM _{2.5}	SO ₂	NO _x
EG-601	---	0.49	---	0.857	81.8
EG-602	---	0.49	---	0.857	81.8

AMBIENT AIR QUALITY STANDARDS - STANDARD NO. 2					
Emission Point ID	Modeled Emission Rates (lbs/hr)				
	CO	Lead	HF	NO ₂	
EG-601	10.46	---	---	---	
EG-602	10.46	---	---	---	

CLASS II PREVENTION OF SIGNIFICANT DETERIORATION - STANDARD NO. 7					
Emission Point ID	Modeled Emission Rates (lbs/hr)				
	PM _{2.5}	PM ₁₀	SO ₂	NO _x	
EG-601	---	0.49	0.857	81.8	
EG-602	---	0.49	0.857	81.8	