



Swimming Pool Final Inspection Checklist

Bureau of Water

Permit Number:	Facility Name:	Date:		
District:	Address:	Time:		
Pre-Inspection Items		Yes	No	N/A
1. Pipe Approved				
2. Required Letters				
3. Fill Water Approved				
4. Sewer Connection Approved				
General Construction Permit Items				
5. Pool dimensions				
6. Shower at major entrance points (as per plans)				
7. Fence or barrier (A&E min. 6', other types min. 4', all gates self closing and can be locked)				
8. Protective barrier provided on any elevated structure or second floor balcony within 10' horizontally of pool				
9. Overhead wiring (if not in conduit must be 20' away from pool horizontally)				
10. Pool wall and floor (smooth, non-slip, single light color)				
11. Deck (meets minimum width requirements, non-slip, sloped 1/4" to 5/8" per foot away from pool, adequately drains to waste)				
12. 6" glazed frost proof tile at water line				
13. No ledges or seats in main body of pool				
14. Adequate handhold from coping or deck				
15. Fill spout location				
16. Fill water backflow prevention (2 X diameter of spout above pool rim or double check valve assembly with proper test results verified)				
17. Hose bibb with ASSE 1024 residential dual check or equiv. (location min. 10" above deck)				
Pool Interior & General Area				
18. Depth markers (correct to nearest 1/2', 4" numerals, include feet or ft, max. 15' intervals, 2' increments of depth, wall & coping, white background color and a total of 12' of white tile shall be included as a part of the depth marker at waterline, no diving tile included in deck depth markers at pools requiring no diving signs)				
19. All appurtenances as per plans (skimmer/gutter, return, main drain, vacuums)				
20. Lifeline if max. depth exceeds 5'6" (marked with permanent non-slip dark color tile stripe min. 4", max. 6", min. 3/4" rope, floats 5" by 6" and a max. of 5' apart)				
21. Ladders (secure and in place, min. three tread design, non-slip)				
22. Handrails (secure, extends over bottom step)				
23. Steps (marked in min. 2" dark colored non-slip stripe or tile)				
24. Water level (middle of skimmer or at gutter lip edge)				
25. Overflow line (6" air gap or in-line check valve)				
26. Adequate deck lighting, GFI per NEC				
27. Underwater lights with GFI				
28. No light fixtures over the water surface				
29. Drinking water fountain as per plans (within 50' of pool, GFI if applicable)				
30. Diving board requirements as per plans				
31. Trash can				
32. Bathroom facilities (proximity, light, vent, drain, no interconnection, shower, water closet, lavatory, toilet paper, liquid or powder soap, towel dispenser or blower hand dryers, shatter-resistant mirrors) or minimum toilet facility				

	YES	NO	N/A
33. Guard chair (every 2000 sq/ft) one rescue tube per chair (replaces life ring and shepherd's crook), one backboard, two blankets, one cervical collar (adult & infant size) or head immobilizer per facility (Type A & E)			
34. 20" USCG approved life ring with throwing line attached with length 1 & 1/2 x width of pool - 50 ft. max. (located in fence within 25' of pool).			
35. Shepherd's crook (12' pole attached w/stainless steel nut and bolt, inside fence within 25' of pool).			
36. First aid kit (must be readily accessible during posted pool hours)			
37. Telephone or emergency notification device (emergency #s at phone, accessible within 200 ft. walking distance, easily accessible)			
38. Filter (make, model)			
39. Pumps (size, make, model, GFI as per NEC)			
40. Chlorinator (make, model)			
41. Automatic controller with chlorine and pH adjustment (model, make, installation, wired to pump flow switch)			
42. Spa has 15 minute timer. Emergency cut-off switch clearly visible and within 25'			
43. Temperature for spa can be monitored in accordance with regulation			
44. Heaters have thermostat control with an automatic cut-off for an upper limit of 104°F			
45. Written instruction for pool & equipment including valve operating schedule (2 copies: 1 posted on equipment room wall with a waterproof cover)			
46. Valves tagged and pipes marked			
47. Flow meter type correct and rate of flow met			
48. Backwash (approved discharge method, receptacle size, 6" air gap or 2 single in-line check valves)			
49. Equipment room (entrance door lockable, adequate illumination and ventilation)			
50. Chemical room (entrance door lockable, adequate illumination and ventilation)			
51. Pool / CPO / spa / bridge signs posted in accordance with regulation			
52. Two "SHALLOW WATER (4")", NO DIVING ALLOWED (6")" signs posted in accordance w/regulation			
53. Pool log (bound and numbered)			
54. A state of South Carolina certified pool operator			
55. Chemical levels: Cl ₂ : 1-5ppm _____ pH: 7.2-7.8 _____ Cyanuric Acid 0-200 ppm _____			

Comments:

Contractor's Representative

Owner's Representative

DHEC Representative

Phone Number

* Facility must call for reinspection _____ Yes _____ NA.

* Facility may open when a permit to operate has been issued by the Department _____ Yes _____ NA.